



TS970, TS971 connection to mini photo cells ELS 500


CONTROL UNIT TS970/TS971



1. 2.1-2.2 original resistor
2. To activate impulse operation
UP-DOWN - Program 1 set to 3
3. If photo cells installed in door way,
learn photo cell crossing point
at control- Activate program 3.2
operate 2 full cycles



Mini photo cells can be activated only with opto safety edge system



Riga Door Systems
we open the world

Malas, Vetras, Marupe LV-2167, Riga district, Latvia; web: www.rigadoors.lv

Designed by

Sheet Format

Date

A3 2026-01-29

TS970-971+MINI PHOTO ELS500

TS970-971+Universal receiver

Rev.
00

Sheet
1 / 1